


JOB:	REPRESENTATIVE:	
UNIT TAG:	ORDER NO.	DATE:
ENGINEER:	SUBMITTED BY:	DATE:
CONTRACTOR:	APPROVED BY:	DATE:



8" Series Type "SU" Heat Exchangers "U" Tube Design

DESCRIPTION

B & G Types "SU" Heat Exchangers are of the shell and tube type. The tube bundle is of "U" bend construction with tube ends expanded into a stationary tube sheet. This construction permits ample expansion or contraction for wide temperature variations. A fluid entering the tubes is heated by steam condensing in the single pass shell. Tube spacers properly support and space each tube for maximum efficiency in steam condensation and drainage.

Standard "SU" Heat Exchangers are constructed according to ASME requirements for pressure and temperatures

A Manufacturers' Data Report for Pressure Vessels, Form No. U-1, as required by the provisions of the ASME Code Rules, is furnished with each unit upon request. This form is signed by an authorized inspector, holding a national Board Commission, and who is employed by an authorized inspection agency, certifying that construction conforms to the latest ASME code for pressure vessels. The ASME "U" symbol is stamped on each vessel. In addition, each unit is registered with the national Board of Boiler and pressure Vessel Inspectors.


RECOMMENDED "SU" HEAT EXCHANGER MODEL NO.

MODEL NO.	HEATING SURFACE (SQ. FT.)		
	TUBE SIDE	SHELL SIDE	
1. Steam Pressure	_____	_____	APPROVALS
2. Fluid Circulated	_____	_____	
3. Total Flow (Expressed in GPM, GRH or lbs./hr)	_____	_____	
4. Temperature In/Out	_____	_____	
5. Heat Load BTU/hr	_____	_____	
6. Pressure Drop (Maximum)	_____	_____	
7. Fouling Factor or Percentage of Additional Surface	_____	_____	
Note: Following applies only to fluids other than water.	_____	_____	
8. Specific Gravity	_____	_____	
9. Specific Heat	_____	_____	
10. Latent Heat	_____	_____	
11. Viscosity**	_____	_____	
12. Thermal Conductivity	_____	_____	

**Expressed in Proper Units and Temperature such as centipoises @ °F

8" Series Type "SU" Heat Exchangers "U" Tube Design

C-121.2B



UNIT NUMBER.	DIMENSIONS IN INCHES											HEATING SURFACE	APPROX. SHIPPING WEIGHT
	2 PASS		2 AND 4 PASS										
	W	R	A	B	E	F	G	H	S	X	Y		
SU82-2	3NPT	5(127)	29-3/8(746)	9-5/8(244)	13(330)	8-5/8(219)	4-15/16(125)	12-1/2(318)	5-9/16(141)	2NPT	1NPT	15 (1.4)	112 (51)
SU83-2	3NPT	5(127)	41-3/8(1051)	9-5/8(244)	25(635)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	2.5NPT	1NPT	23 (2.1)	148 (67)
SU84-2	3NPT	5(127)	53-3/8(1356)	9-5/8(244)	37(940)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	3NPT	1NPT	32 (3)	184 (83)
SU85-2	3NPT	5(127)	65-3/8(1661)	9-5/8(244)	49(1245)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1NPT	41 (3.8)	220 (100)
SU86-2	3NPT	5(127)	77-3/8(1965)	9-5/8(244)	61(1549)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	49 (4.6)	256 (116)
SU87-2	3NPT	5(127)	89-3/8(2270)	9-5/8(244)	73(1854)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	58 (5.4)	292 (132)
SU88-2	3NPT	5(127)	101-3/8(2575)	9-5/8(244)	85(2159)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	67 (6.2)	328 (149)
SU89-2	3NPT	5(127)	113-3/8(2880)	9-5/8(244)	97(2464)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	75 (7)	364 (165)

UNIT NUMBER.	DIMENSIONS IN INCHES													HEATING SURFACE	APPROX. SHIPPING WEIGHT
	4 PASS				2 AND 4 PASS										
	L	M	N	Z	A	B	E	F	G	H	S	X	Y		
SU82-2	2(51)	4(102)	3-1/2(89)	2NPT	29-3/8(746)	9-5/8(244)	13(330)	8-5/8(219)	4-15/16(125)	12-1/2(318)	5-9/16(141)	2NPT	1NPT	15 (1.4)	112 (51)
SU83-2	2(51)	4(102)	3-1/2(89)	2NPT	41-3/8(1051)	9-5/8(244)	25(635)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	2.5NPT	1NPT	23 (2.1)	148 (67)
SU84-2	2(51)	4(102)	3-1/2(89)	2NPT	53-3/8(1356)	9-5/8(244)	37(940)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	3NPT	1NPT	32 (3)	184 (83)
SU85-2	2(51)	4(102)	3-1/2(89)	2NPT	65-3/8(1661)	9-5/8(244)	49(1245)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1NPT	41 (3.8)	220 (100)
SU86-2	2(51)	4(102)	3-1/2(89)	2NPT	77-3/8(1965)	9-5/8(244)	61(1549)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	49 (4.6)	256 (116)
SU87-2	2(51)	4(102)	3-1/2(89)	2NPT	89-3/8(2270)	9-5/8(244)	73(1854)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	58 (5.4)	292 (132)
SU88-2	2(51)	4(102)	3-1/2(89)	2NPT	101-3/8(2575)	9-5/8(244)	85(2159)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	67 (6.2)	328 (149)
SU89-2	2(51)	4(102)	3-1/2(89)	2NPT	113-3/8(2880)	9-5/8(244)	97(2464)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	75 (7)	364 (165)

UNIT NUMBER.	DIMENSIONS IN INCHES												HEATING SURFACE	APPROX. SHIPPING WEIGHT
	6 PASS													
	P	T	V	A	B	E	F	G	H	S	X	Y		
SU82-2	3(76)	3-3/4(95)	2NPT	29-3/8(746)	9-5/8(244)	13(330)	8-5/8(219)	4-15/16(125)	12-1/2(318)	5-9/16(141)	2NPT	1NPT	12 (1.1)	112 (51)
SU83-2	3(76)	3-3/4(95)	2NPT	41-3/8(1051)	9-5/8(244)	25(635)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	2.5NPT	1NPT	19 (1.8)	148 (67)
SU84-2	3(76)	3-3/4(95)	2NPT	53-3/8(1356)	9-5/8(244)	37(940)	8-5/8(219)	4-15/16(125)	12-1/2(318)	6-1/8(156)	3NPT	1NPT	26 (2.4)	184 (83)
SU85-2	3(76)	3-3/4(95)	2NPT	65-3/8(1661)	9-5/8(244)	49(1245)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1NPT	33 (3.1)	220 (100)
SU86-2	3(76)	3-3/4(95)	2NPT	77-3/8(1965)	9-5/8(244)	61(1549)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	41 (3.8)	156 (71)
SU87-2	3(76)	3-3/4(95)	2NPT	89-3/8(2270)	9-5/8(244)	73(1854)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	4FLG	1.25NPT	48 (4.5)	292 (132)
SU88-2	3(76)	3-3/4(95)	2NPT	101-3/8(2575)	9-5/8(244)	85(2159)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	55 (5.1)	328 (149)
SU89-2	3(76)	3-3/4(95)	2NPT	113-3/8(2880)	9-5/8(244)	97(2464)	8-5/8(219)	4-15/16(125)	12-1/2(318)	8-13/16(224)	6FLG	1.25NPT	62 (5.8)	364 (165)

Dimensions are subject to change. If exact dimensions are needed for layout, write for certified prints.

DESIGN PRESSURES - ASME CONSTRUCTION CAST IRON & BRASS UNITS

DESIGN PRESSURES				DESIGN TEMPERATURES*	
TUBE SIDE		SHELL SIDE		TUBE & SHELL SIDE	
DESIGN	TEST	DESIGN	TEST	CAST IRON	BRASS
150 psi	300 psi	150 psi	300 psi	375 °F	300 °F

MATERIALS

PART	STANDARD CAST IRON UNIT	BRASS UNIT
	2, 4 & 6 Pass	2 & 4 Pass
Head	Cast Iron	Cast Brass
Shell	Steel	Steel
Tube Sheets	Steel	Royal Naval Brass
Tubing	Cooper 3/4" O.D.	Cooper 3/4" O.D.
Tube Supports	Steel	Steel
Nuts & Bolts	Steel	Steel

TYPICAL INSTALLATION OF "SU" HEAT EXCHANGER


Steam Hammer can cause serious damage to the tubes of any Heat Exchanger. A careful consideration of the following points before an installation is made can prevent costly repairs which may be caused by steam hammer.

(a) A vacuum breaker and/or vent, should be used in accordance with the type of system installed.

(b) The proper trap for the steam system installed should be used. (c) The trap and the condensate return line to the trap should be properly sized for the total capacity of the converter.

(d) The trap should be sized for the pressure at the trap, not the inlet pressure to the steam controller.

CAUTION: A properly sized relief valve must be installed on the heater water side to protect heat exchangers from possible damage due to volumetric expansion.



Xylem Inc.
8200 N. Austin Avenue
Morton Grove, IL 60053
Phone: (847)966-3700
Fax: (847)965-8379
www.bellgossett.com

xylem
Let's Solve Water

Bell & Gossett is a trademark of Xylem Inc. or one of its subsidiaries.
© 2013 Xylem Inc.